

Spa, Wading, or Recirculating Spray Pool Log Sheet

Pool Name: _____ Month: _____ Year: _____ Size of Pool (gallons): _____ Flow Rate Required (GPM): _____
 Type of Disinfectant: _____ Minimum of 3.0 PPM if inorganic chlorine, 3.5 PPM if stabilized or organic, and 4.0 PPM if Bromine.

Date	Daily Tests					Weekly Tests		Chemicals Added		Maintenance & Notes				
	Water Clarity	Disinfectant PPM			Combined Chlorine < 50% free	pH 7.2-8.0	Temp Max 104° F	Alkalinity Rec. Range 60-160 PPM	Cyanuric Acid if used < 90	Quantity of Disinfectant Added	Other Chemicals Added	Flow Rate & Date of Back-wash	Vacuum or Brush	Contaminant Episode
1														
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														

Date	Daily Tests					Weekly Tests		Chemicals Added		Maintenance & Notes				
	Water Clarity	Disinfectant PPM			Combined Chlorine < 50% free	pH 7.2-8.0	Temp Max 104° F	Alkalinity Rec. Range 60-160 PPM	Cyanuric Acid if used < 90	Quantity of Disinfectant Added	Other Chemicals Added	Flow Rate & Date of Back-wash	Vacuum or Brush	Contaminant Episode
16														
17														
18														
19														
20														
21														
22														
23														
24														
25														
26														
27														
28														
29														
30														
31														